



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 9, 2009

Re: Ross County
Carousel Court Mobile Home Park
Self Monitoring Report Violations
EPA Permit No. 0PV00008*ED
Correspondence (PWW)

Mr. Asa Elsea
Elsea, Inc.
P.O. Box 588
2015 Stone Ridge Drive
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring report covering the months of January through April 2009 for the Carousel Court mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	30D Conc	10	11.	3/1/2009

* 30 D Conc is equal to average monthly concentration limit.

A recent reconnaissance inspection of the facility on May 28, 2009 revealed that the former trash trap converted into a lift station was full and overflowing into the aeration basin. According to recent discussions with plant operator, Tom Bouts, there have been several problems with the grinder pumps as well as the equalization basin pumps. To date the new upgrades at the facility have not been fully operational and solids continue to be washed out into the filter beds. Failure to utilize all treatment components is an illegal bypass which is in direct violation of Part III of your permit and shall be properly reported according to your permit. Please provide documentation explaining why the pumps were out of service and immediate actions which will be taken to ensure all treatment units are fully operational.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script, appearing to read "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Tom Bouts, Operator