



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 5, 2009

Re: Ross County
Carousel Court Mobile Home Park
Self Monitoring Report Violations
EPA Permit No. 0PV00008*ED
Correspondence (PWW)

Mr. Asa Elsea
Elsea, Inc.
P.O. Box 588
2015 Stone Ridge Drive
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring reports covering the months of October through November 2008 for the Carousel Court MHP. Review of the monthly reports showed the failure to submit daily precipitation values for the two month reporting period. Those days with no precipitation should simply be reported as "AA" and in the comments section list the lowest level that rainfall can be recorded. Please follow the same reporting procedure that would be used for chemical analysis which would be below the detection limit. The monitoring requirements of your permit require the reporting of daily precipitation and zero or simply leaving blank is not acceptable.

As a result of the installation of your upgrades the interim effluent limits which were a condition of your orders will no longer be effective beginning January 1, 2009. As of this date you will be expected to meet the final effluent limits as listed in your NPDES permit.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Tom Bouts, Operator
c: Ross County Health Department