

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 30, 2011

**Re:** Ross County  
Country Woods Estates  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PV00025\*BD  
Correspondence (PWW)

Mr. John Cook, Owner  
Country Woods Estates MHP  
2150 Stone Road  
Chillicothe, Ohio 45601

Dear Mr. Cook:

We have reviewed your self-monitoring reports covering the months of October 2010 through March 2011 for the Country Woods Estates Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	9.65	2/24/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	9.65	2/1/2011
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.141	.19592	2/24/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0939	.19592	2/1/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.56	11/1/2010
001	00530	Total Suspended Solids	1D Conc	18	19.	3/17/2011
001	00530	Total Suspended Solids	30D Conc	12	19.	3/1/2011
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	10.7	3/17/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	10.7	3/1/2011
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.141	.23542	3/17/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0939	.23542	3/1/2011
001	80082	CBOD 5 day	1D Conc	15	18.	3/17/2011
001	80082	CBOD 5 day	30D Conc	10	18.	3/1/2011


\* 7 D Conc is equal to average weekly concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response has been sent prior to this letter no further action is required.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

c: Wayne Grigsby