



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 9, 2010

**Re:** Ross County  
Country Woods Estates  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PV00025\*BD  
Correspondence (PWW)

Mr. John Cook, Owner  
Country Woods Estates MHP  
2150 Stone Road  
Chillicothe, Ohio 45601

Dear Mr. Cook:

We have received your self-monitoring reports covering the months of August through October 2010 for the Country Woods Estates Mobile Home Park. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.46	8/1/2010
001	31616	Fecal Coliform	30D Conc	1000	6500.	8/1/2010
001	31616	Fecal Coliform	1D Conc	2000	6500.	8/19/2010
<b>September 2010:</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	12.2	9/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0939	.26538	9/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	12.2	9/23/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.141	.26538	9/23/2010

- \* 1 D Conc is equal to the maximum daily concentration limit.
- 1 D Qty is equal to the maximum daily loading limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator