



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 27, 2010

Re: Ross County
Country Woods Estates
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00025*BD
Correspondence (PWW)

Mr. John Cook, Manager
Country Woods Estates MHP
2150 Stone Road
Chillicothe, Ohio 45601

Dear Mr. Cook:

We have received your self-monitoring reports covering the months of October through December 2009 for the Country Woods Estates mobile home park. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	4.65	10/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0939	.09971	10/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	4.65	10/15/2009

*1 D Conc is equal to the maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.
30 D Qty is equal to average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of the above violations has been sent to this office no further action is required.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator