



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 14, 2009

**Re: Ross County**  
Country Woods Estates  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PV00025\*BD  
Correspondence (PWW)

Mr. John Cook, Owner  
Country Woods Estates MHP  
2150 Stone Road  
Chillicothe, Ohio 45601

Dear Mr. Cook:

We have received your self-monitoring reports covering the months of May through August 2009 for the Country Woods Estates mobile home park. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Station          | Reporting Code | Parameter               | Limit Type | Limit  | Reported Value | Violation Date |
|------------------|----------------|-------------------------|------------|--------|----------------|----------------|
| 001              | 00530          | Total Suspended Solids  | 30D Conc   | 12     | 46.            | 5/1/2009       |
| 001              | 00530          | Total Suspended Solids  | 30D Qty    | 0.564  | .87334         | 5/1/2009       |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 30D Conc   | 2.0    | 25.            | 5/1/2009       |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 30D Qty    | 0.0939 | .47464         | 5/1/2009       |
| 001              | 80082          | CBOD 5 day              | 30D Conc   | 10     | 37.            | 5/1/2009       |
| 001              | 80082          | CBOD 5 day              | 30D Qty    | 0.47   | .70247         | 5/1/2009       |
| 001              | 00530          | Total Suspended Solids  | 1D Conc    | 18     | 46.            | 5/21/2009      |
| 001              | 00530          | Total Suspended Solids  | 1D Qty     | 0.845  | .87334         | 5/21/2009      |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 1D Conc    | 3.0    | 25.            | 5/21/2009      |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 1D Qty     | 0.141  | .47464         | 5/21/2009      |
| 001              | 80082          | CBOD 5 day              | 1D Conc    | 15     | 37.            | 5/21/2009      |
| 001              | 00300          | Dissolved Oxygen        | 1D Conc    | 5.0    | 4.7            | 5/21/2009      |
| <b>June 2009</b> |                |                         |            |        |                |                |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 30D Conc   | 2.0    | 9.59           | 6/1/2009       |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 30D Qty    | 0.0939 | .24367         | 6/1/2009       |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 1D Conc    | 3.0    | 9.59           | 6/24/2009      |
| 001              | 00610          | Nitrogen, Ammonia (NH3) | 1D Qty     | 0.141  | .24367         | 6/24/2009      |

\*1 D Conc is equal to the maximum daily concentration limit.  
1D Qty is equal to the maximum daily loading limit.  
30 D Conc is equal to average monthly concentration limit.  
30 D Qty is equal to average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation to these violations has been sent to our office no response is necessary to this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator