



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 14, 2009

Re: Ross County
Village of Frankfort
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PB00014*GD
Correspondence (PWW)

Mayor and Council
Village of Frankfort
P.O. Box 351
Frankfort, Ohio 45628

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through August 2009 for the Country Woods Estates mobile home park. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	7D Conc	2000	4600.	8/22/2009

*7 D Conc is equal to the average weekly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation to these violations has been sent to our office no response is necessary to this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Shawn White, Operator