



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6480
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 27, 2010

Re: Ross County
Village of Clarksburg
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PA00001*GD
Correspondence (PWW)

Mayor and Council
Village of Clarksburg
State Route 138
Clarksburg, Ohio 43115

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October through December 2009 for the Village of Clarksburg's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Conc	18	24.	11/1/2009
001	00530	Total Suspended Solids	7D Qty	4.1	4.90536	11/1/2009

*7 D Conc is equal to average weekly concentration limit.

7 D Qty is equal to average weekly loading limit.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent to our office no further action is required.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Gary Sollars, Operator, Chillicothe WWTP