



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 19, 2008

**Re:** Ross County  
Huntington Schools  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PT00007\*FD  
Correspondence (PWW)

Mr. John Barr, Superintendent  
Huntington Local School District  
188 Huntsman Road  
Chillicothe, Ohio 45601

Dear Mr. Barr:

We have received your self-monitoring report covering the months September through December 2007 for the Huntington Schools wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	22.25	12/1/2007
001	00530	Total Suspended Solids	7D Conc	18	30.	12/1/2007
001	00530	Total Suspended Solids	7D Conc	18	38.	12/8/2007

\*7 D Conc is equal to average weekly concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Joe King, Technical Supervisor