



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 14, 2009

**Re:** Ross County  
Kenowa Village MHP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PV00010\*CD  
Correspondence (PWW)

Ms. Gayle Scott, Owner  
555 Greenlawn Avenue  
Columbus, Ohio 43223

Dear Ms. Scott:

We have received your self-monitoring reports covering the months of May through August 2009 for the Kenowa Village mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	5.0	4.3	8/13/2009
001	00300	Dissolved Oxygen	1D Conc	5.0	2.6	8/20/2009

\*1D Conc is equal to the maximum daily concentration limit.  
7 D Conc is equal to average weekly concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Andrew Griner, Operator, Winelco Inc.