



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 19, 2008

Re: Ross County
Kenowa Village MHP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00010*BD
Correspondence (PWW)

Ms. Gayle Scott, Owner
555 Greenlawn Avenue
Columbus, Ohio 43223

Dear Ms. Scott:

We have received your self-monitoring report covering the months of September through December 2007 for the Kenowa Village mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	.019	.08	9/13/2007
001	50060	Chlorine, Total Residual	1D Conc	.019	.07	9/27/2007
October 2007						
001	50060	Chlorine, Total Residual	1D Conc	.019	.07	10/4/2007

*1D Conc is equal to the maximum daily concentration limit.

We have reviewed your report addressing the reasons for the above violations and the actions taken to prevent further occurrences. The recent installation of the UV disinfection system will provide better disinfection and eliminate the presence of residual chlorine in your effluent. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Andrew Griner, Operator, Winelco, Inc.