



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 24, 2010

Re: Ross County
Mays Mobile Home Park
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00017*DD
Correspondence (PWW)

Ms. Darlene Huff, Owner
Mays Mobile Home Park
3168 South Bridge Street
Chillicothe, Ohio 45601

Dear Ms. Huff:

We have received your self-monitoring reports covering the months of January through May for the May's MHP wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.038	2.	5/14/2010
001	50060	Chlorine, Total Residual	1D Conc	0.038	2.	5/28/2010

*1 D Conc is equal to the maximum daily concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent to our office no further correspondence is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Jim Hill, Operator