

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 1, 2011

Re: Ross County  
Paint Valley High School  
Self-Monitoring Report Violations  
Ohio EPA Permit #0PT00054\*BD  
Correspondence (PWW)

Mr. Gary Uhrig, Supt.  
Paint Valley School  
7454 State Route 50  
Bainbridge, Ohio 45612

Dear Mr. Uhrig:

We have reviewed your self-monitoring reports covering the months of October 2010 through March 2011 for the Paint Valley High School Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	79.7	1/1/2011
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	79.7	1/1/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.07	1.01993	1/1/2011
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.11	1.01993	1/1/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	14.9	2/1/2011
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	14.9	2/22/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.07	.48839	2/1/2011
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.11	.48839	2/22/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.55	12/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.07	.08687	12/1/2010

\*7D Conc is equal to average weekly concentration limit.  
30D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response has been sent prior to this letter, no further action is required.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh