



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 23, 2011

Re: Ross County
Paint Valley School
Permit #OPT00054*BD
WWTP Inspection
Correspondence (PWW)

Mr. Gary E. Uhrig, Superintendent
Paint Valley Local School District
7454 U.S. Route 50
Bainbridge, Ohio 45612

Dear Mr. Uhrig:

On March 14, 2011, I conducted an inspection of the Paint Valley High School wastewater treatment plant (WWTP). Kendall Evans represented the school and assisted me during the inspection. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPR00054*BD. A copy of the inspection report is attached.

If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure: Compliance Inspection Report

c: Wayne Grigsby, Grigsby Environmental Consulting Services, LLC

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00054*BD	OH0127752	March 14, 2011	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Paint Valley High School 7454 U.S. Route 50 Bainbridge, Ohio 45612	1:35 p.m.	February 1, 2007
	Exit Time	Permit Expiration Date
	2:05 p.m.	January 31, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Wayne Grigsby, Operator	(740) 703-5180
Name, Address and Title of Responsible Official	Phone Number
Gary Uhrig, Superintendent 7454 U.S. Route 50 Bainbridge, Ohio 45612	(740) 634-2826

C. AREAS EVALUATED DURING INSPECTION

<u> </u> S Permit	<u> </u> S Flow Measurement	<u> </u> N/A Pretreatment
<u> </u> S Records/Reports	<u> </u> N/A Laboratory	<u> </u> N/A Compliance Schedules
<u> </u> S Operations & Maintenance	<u> </u> S Effluent/Receiving Waters	<u> </u> S Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> S Sludge Storage/Disposal	<u> </u> Other
<u> </u> N/A Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)



Jack Knapp, Inspector, Ohio EPA, Southeast District Office

3/18/11

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/24/11

Date



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 24, 2010

Re: Ross County
Paint Valley High School
Self-Monitoring Report Violations
Ohio EPA Permit No. OPT00054*BD
Correspondence (PWW)

Mr. Gary Uhrig, Superintendent
Paint Valley School
7454 State Route 50
Bainbridge, Ohio 45612

Dear Mr. Uhrig:

We have received your self-monitoring report covering the months of January through April 2010 for the Paint Valley High School's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	26.1	1/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.07	.69152	1/1/2010
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	26.1	1/15/2010
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.11	.69152	1/15/2010

- * 7 D Qty is equal to the average weekly loading limit.
- 7 D Conc is equal to the average weekly concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation to these violations has been sent to our office no response is necessary to this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator