



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 23, 2009

**Re:** Ross County  
Queen City MHP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PV00028\*DD  
Correspondence (PWW)

Mr. Joe Molnar, Owner  
Queen City Mobile Home Park  
P.O. Box 1992  
Chillicothe, Ohio 45601

Dear Mr. Molnar:

We have received your self-monitoring report covering the months of July through October 2009 for the Queen City's mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit as well as the failure to submit reports in August and September. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	8/25/2009
<b>September 2009</b>						
001	31616	Fecal Coliform	30D Conc	1000	3200.	9/1/2009
001	31616	Fecal Coliform	1D Conc	2000	3200.	9/22/2009

\* 1D Conc is equal to the maximum daily concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **14 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. The missing DMR reports should be completed and submitted to Columbus for entry into our database.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Jeff Raines, Operator