



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

November 7, 2008

Re: Ross County
Queen City MHP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00028*BD
Correspondence (PWW)

Mr. Joe Molnar, Owner
Queen City Mobile Home Park
P.O. Box 1992
Chillicothe, Ohio 45601

Dear Mr. Molnar:

We have received your self-monitoring report covering the months of June through September 2008 for the Queen City's mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	4900.	6/1/2008
001	31616	Fecal Coliform	1D Conc	2000	4900.	6/17/2008
August 2008:						
001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	14.	8/1/2008
001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.137	1.90764	8/1/2008
001	31616	Fecal Coliform	30D Conc	1000	4700.	8/1/2008
001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	8.6	8/12/2008
001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.205	1.17184	8/12/2008
001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	19.4	8/26/2008
001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.205	2.64344	8/26/2008
001	31616	Fecal Coliform	1D Conc	2000	4700.	8/26/2008

- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Jeff Raines, Operator