





John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Paulding County  
Oakwood Village Water  
Community Water System  
PWS ID# OH6300312

January 29, 2013

Mr. John Keyes  
Oakwood Village Water  
228 North First Street  
P. O. Box 457  
Oakwood, Ohio 45873

Dear Mr. Keyes:

This office provided a notice of violation for failing to comply with the operational requirements of Ohio Administrative Code (OAC) 3745-83-01 during the month of November 2012.

The notice stated that in violation of 3745-83-01 (C) (1), the public water system failed to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

On January 24, 2013, your Operator of Record, Tim Phillips, provided copies of bench sheets and a written statement that the numbers provided in the MOR were an administrative error, and not reflective of the actual chlorine residuals. Upon review of the bench sheets, our notice of violation for November 2012, is hereby rescinded.

If you have any questions, please contact this office.

Sincerely,

A handwritten signature in black ink, appearing to read "CR", written over a white background.

Chris Riddle  
Division of Drinking and Ground Waters

/llr

pc: Paulding County Health Department  
DDAGW, NWDO File

