



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 15, 2008

**Re:** Ross County  
Village of South Salem  
Self-Monitoring Report Violations  
Ohio EPA Permit No.0PA00018\*BD  
Correspondence (PWW)

Mayor and Council  
Village of South Salem  
P.O. Box 29  
South Salem, Ohio 45681

Dear Mayor and Council:

We have received your self-monitoring report covering the months of November through March 2008 for the Village of South Salem's wastewater lagoons. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Station | Reporting Code | Parameter              | Limit Type | Limit | Reported Value | Violation Date |
|---------|----------------|------------------------|------------|-------|----------------|----------------|
| 001     | 00530          | Total Suspended Solids | 30D Qty    | 7.63  | 10.2195        | 11/1/2007      |
| 001     | 00530          | Total Suspended Solids | 30D Qty    | 7.63  | 7.84858        | 12/1/2007      |
| 001     | 80082          | CBOD 5 day             | 30D Qty    | 2.94  | 5.0934         | 12/1/2007      |
| 001     | 00530          | Total Suspended Solids | 7D Qty     | 10.6  | 10.7917        | 12/8/2007      |
| 001     | 80082          | CBOD 5 day             | 7D Qty     | 4.7   | 9.27113        | 12/8/2007      |
| 001     | 00530          | Total Suspended Solids | 30D Qty    | 7.63  | 7.84858        | 1/1/2008       |
| 001     | 80082          | CBOD 5 day             | 30D Qty    | 2.94  | 4.66009        | 1/1/2008       |

\* 7 D Qty is equal to a average weekly loading limit.  
30 D Qty is equal to the average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent to this office, please disregard this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator