



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

February 19, 2008

**Re:** Ross County  
ODNR - Tar Hollow State Park  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PP00037\*CD  
Correspondence (PWW)

Mr. Marty Hall, Park Manager  
ODNR - Tar Hollow State Park  
16396 Tar Hollow Road  
Laurelville, Ohio 43135

Dear Mr. Hall:

We have received your self-monitoring reports covering the months of July through December 2007 for the Tar Hollow State Park wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	23.	8/1/2007
001	00530	Total Suspended Solids	7D Conc	18	23.	8/1/2007
<b>October 2007</b>						
001	00530	Total Suspended Solids	30D Conc	12	20.	10/1/2007
001	00530	Total Suspended Solids	7D Conc	18	20.	10/8/2007

\*30 D Conc is equal to average monthly concentration limit.

We have reviewed your report explaining the reasons these violations occurred and the actions being taken to prevent future occurrences. Hopefully these actions will prevent any reoccurrence and your actions to maintain permit compliance are much appreciated. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Steve Young, Operator