



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 27, 2010

Re: Ross County
P.H. Glatfelter Company
Self-Monitoring Report Violations
Ohio EPA Permit No. 01A00002*ID
Correspondence (IWW)

Mr. Jim Flanders, Environmental Engineer
P.H. Glatfelter Company
P.O. Box 2500
Chillicothe, Ohio 45601

Dear Mr. Flanders:

We have received your self-monitoring reports covering the months of October through December 2009 for the Chillicothe paper mill's industrial wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	1D Conc	172	230.	12/16/2009
001	00530	Total Suspended Solids	1D Qty	21089	23069.5	12/16/2009
001	00530	Total Suspended Solids	1D Conc	172	370.	12/20/2009
001	00530	Total Suspended Solids	1D Qty	21089	36551.7	12/20/2009

*1 D Conc is equal to the maximum daily concentration limit.

1 D Qty is equal to the maximum daily loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation to these violations has been sent to our office no response is necessary to this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh