



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

September 15, 2009

Re: Tuscarawas County
Baltic WWTP
Notice of Violation
OPB00067, OH0047783
Correspondence (PWW)

Mayor and Council
Village of Baltic
P.O. Box 320
Baltic, Ohio 43804-0320

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through July 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
May 2009:					
001	Average	Phosphorus, Total	5.4	mg/l	1.0
001	Average	Phosphorus, Total	2.31	kg/day	0.38
June 2009:					
001	Average	Phosphorus, Total	3.0	mg/l	1.0
001	Average	Phosphorus, Total	0.98	kg/day	0.38
July 2009:					
001	Average	Phosphorus, Total	6.6	mg/l	1.0
001	Average	Phosphorus, Total	1.35	kg/day	0.38
001	Average	Suspended Solids	17	mg/l	12
001	Weeks 3&4	Suspended Solids	19-31	mg/l	18
001	Week 4	Suspended Solids	8.02	kg/day	6.81

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the above-referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 23, 2009

Re: Tuscarawas County
Baltic WWTP
Notice of Violation
OPB00067, OH0047783
Correspondence (PWW)

Mayor and Council
Village of Baltic
P.O. Box 320
Baltic, Ohio 43804-0320

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of August through October 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
August 2009:					
001	Average	Phosphorus, Total	5.3	mg/l	1.0
001	Average	Phosphorus, Total	1.1	kg/day	0.38
001	Average	CBOD ₅	11	mg/l	10
001	Week 3	CBOD ₅	18	mg/l	15
September 2009:					
001	Average	Phosphorus, Total	3.4	mg/l	1.0
001	Average	Phosphorus, Total	0.86	kg/day	0.38
October 2009:					
001	Average	Phosphorus, Total	9.3	mg/l	1.0
001	Average	Phosphorus, Total	2.8	kg/day	0.38


Ohio EPA received a late Discharge Monitoring Report (DMR) for your facility for outfalls 001, 581 and 601 for the month of **September 2009**. Submission of DMR data is a requirement of your NPDES permit (Part II, Item 4 – Reporting). A DMR report is due no later than the 20th day of the month.

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations, monitoring and/or reporting requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer, Environmental Specialist 2
Division of Surface Water

JMW/dh

c: Mr. Tim Griffith, Superintendent, Village of Baltic