



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 10, 2010

Re: Tuscarawas County
Baltic WWTP
Notice of Violation
OPB00067, OH0047783
Correspondence (PWW)

Mayor and Council
Village of Baltic
P.O. Box 320
Baltic, Ohio 43804-0320

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of November 2009 through January 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
January 2010:					
001	Average	Suspended Solids	5.79	kg/day	4.54
001	1/22	Suspended Solids	33	mg/l	18
001	1/22	Suspended Solids	20.3	kg/day	6.81

We have received a report addressing the reasons for the aforementioned violations. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if *satisfactory progress is not made*, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte
Chemical Engineer, Environmental Specialist 2
Division of Surface Water

JMW/mlm

c: Mr. Tim Griffith, Superintendent, Village of Baltic