

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 25, 2011

**Re:** Tuscarawas County  
Baltic WWTP  
Notice of Violation  
OPB00067, OH0047783  
Correspondence (PWW)

Mayor and Council  
Village of Baltic  
P.O. Box 320  
Baltic, Ohio 43804-0320

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of September through November 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>September 2010:</b>					
001	Average	Phosphorus, Total	1.8	mg/l	1.0
001	Average	Phosphorus, Total	0.42	kg/day	0.38
001	Week 4	Fecal Coliform	None	#/100ml	Monitoring required 1/week
001	Week 4	CBOD <sub>5</sub>	1/week	mg/l	Monitoring required 2/week
001	Week 4	Suspended Solids	1/week	mg/l	Monitoring required 2/week
<b>October 2010:</b>					
001	Average	Phosphorus, Total	5.4	mg/l	1.0
001	Average	Phosphorus, Total	1.39	kg/day	0.38

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the aforementioned violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

A handwritten signature in cursive script that reads "Jennifer M. Witte".

Jennifer M. Witte  
Chemical Engineer, Environmental Specialist 2  
Division of Surface Water

JMW/dh

c: Mr. Tim Griffith, Superintendent, Village of Baltic