



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 9, 2008

**Re: Tuscarawas County
Dover WWTP
Notice of Violation
OPD00005, OH0024945
Correspondence (PWW/Major)**

Mayor and Council
City of Dover
West Third Street
Dover, Ohio 44622

Dear Mayor and Council:

We have received your self-monitoring report covering the months of December 2007 through April 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
December 2007					
001	Average	Suspended Solids	317	kg/day	170
001	Average	Suspended Solids	54.5	mg/l	30
001	12/5	Oil and Grease	33.9	mg/l	10
001	Weeks 3-4	CBOD5	235-261	kg/day	227
001	Weeks 3-4	CBOD5	44-45	mg/l	40
001	Weeks 3-4	Suspended Solids	75-104	mg/l	45
001	Weeks 3-4	Suspended Solids	408-607	kg/day	256
January 2008					
001	Average	Suspended Solids	43	mg/l	30
001	Weeks 1-2	Suspended Solids	47-69	mg/l	45
001	Average	Suspended Solids	223	kg/day	170
001	Week 1	Suspended Solids	348	kg/day	256
001	1/1	Oil and Grease	11.8	mg/l	10
001	Average	CBOD5	206	kg/day	142
001	Average	CBOD5	40	mg/l	25
001	Weeks 1-2	CBOD5	46-63	mg/l	40
001	Weeks 1-2	CBOD5	245-319	kg/day	227
February 2008					
001	Average	Suspended Solids	46	mg/l	30
001	Week 1	Suspended Solids	107	mg/l	45
001	Average	Suspended Solids	337	kg/day	170
001	Week 1	Suspended Solids	813	kg/day	256
001	Week 1	CBOD5	279	kg/day	227

Outfall	Date	Parameter	Reported	Units	Permit Limitation
March 2008					
001	Average	Suspended Solids	105	mg/l	30
001	Average	Suspended Solids	1190	kg/day	170
001	Weeks 1-4	Suspended Solids	53-187	mg/l	45
001	Weeks 1-4	Suspended Solids	613-1938	kg/day	256
001	Weeks 1-3	CBOD5	258-426	kg/day	227
001	Week 2	CBOD5	41	mg/l	40
001	Average	CBOD5	307	kg/day	142
001	Average	CBOD5	27	mg/l	25
001	3 Days	pH, Minimum	6.15-6.46	S.U.	6.5 Minimum
April 2008					
001	Week 1	CBOD5	369	kg/day	227
001	Average	Suspended Solids	570	kg/day	170
001	Weeks 1&3	Suspended Solids	51-140	mg/l	45
001	Weeks 1,3&4	Suspended Solids	308-1712	kg/day	256
001	Average	Suspended Solids	55	mg/l	30

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh

c: Mr. Bill CRAIGO, WWTP Supt., City of Dover
c: Mr. Dave DOUGLAS, Service Director, City of Dover