

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 25, 2011

Re: Tuscarawas County
Dover WWTP
Notice of Violation
OPD00005, OH0024945
Correspondence (PWW/Major)

Mayor and Council
City of Dover
West Third Street
Dover, Ohio 44622

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October and November 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
October 2010:					
001	10/28	Dissolved Oxygen	4.13	mg/l	5.0 Minimum
November 2010:					
001	11/6	Dissolved Oxygen	3.91	mg/l	5.0 Minimum

We have received a report addressing the reasons for the aforementioned violations. No additional information is needed at this time.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the

environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh

- c: Mr. Bill Craigo, WWTP Supt., City of Dover
- c: Mr. Dave Douglas, Service Director, City of Dover