



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortleski, Director

October 3, 2007

Re: Tuscarawas County
Eagle Auto Truck Plaza, Ltd.
Notice of Violation (OPR00124, OH0120804)
Correspondence (PWW)

Ms. Linda D. Christmas
Eagle Auto Truck Plaza, Ltd.
217 16th Street SW
New Philadelphia, Ohio 44663

Dear Ms. Christmas:

We have received your self-monitoring reports covering the months of March 2006 through March 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
May 2006:					
001	2 Days	Chlorine Residual	0.22-0.34	mg/l	0.019
June 2006:					
001	2 Days	Chlorine Residual	0.27-0.32	mg/l	0.019
July 2006:					
001	2 Days	Chlorine Residual	0.28-0.36	mg/l	0.019
August 2006:					
001	2 Days	Chlorine Residual	0.21-0.26	mg/l	0.019
001	Average	Fecal Coliform	1800	#/100ml	1000
September 2006:					
001	2 Days	Chlorine Residual	0.28-0.31	mg/l	0.019
October 2006:					
001	2 Days	Chlorine Residual	0.19-0.23	mg/l	0.019
December 2006:					
001	12/8	Odor, Severity	None	Units	Reporting required 1/day

In addition, please be aware that we have not received your self-monitoring reports covering the months of April through August 2007. Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the aforementioned referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer Witte
Chemical Engineer - Environmental Specialist
Division of Surface Water

JMW/dh

c: Ron Lambert, Technical Supervisor