



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

March 9, 2011

**Re:** Tuscarawas County  
Kerr Allotment WWTP  
Notice of Violation  
OPG00031, OH0048437  
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer  
Tuscarawas County Metropolitan Sewer District  
9944 Wilkshire Blvd., NE  
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of December 2010 and January 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>December 2010:</b>					
001	Average	Suspended Solids	1.21	kg/day	0.90

We have received your report addressing the reasons for the aforementioned violation. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte  
Chemical Engineer - Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District