



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 6, 2008

Re: Tuscarawas County
Mineral City WWTP
Notice of Violation
0PB00053, OH0021504
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer
Tuscarawas County Metropolitan Sewer District
9944 Wilkshire Blvd., NE
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of November 2007 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
February 2008:					
001	Week 1	Suspended Solids	36	kg/day	26
March 2008:					
001	Average	Suspended Solids	20	kg/day	17
001	Week 3	Suspended Solids	34	kg/day	26
June 2008:					
001	7 Days	Flow Rate	AD	MGD	Reporting required 1/day

We have received report addressing the aforementioned violations. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh

c: Mr. Jack Shalosky, Tuscarawas County Water and Sewer District