



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 6, 2008

Re: Tuscarawas County
Ravens Trailer Sales, Inc.
Notice of Violation
0PR00140, OH0127728
Correspondence (IWW)

Mr. Rufus Hall, Manager
Ravens Trailer Sales, Inc.
6332 Columbia Road, NW
P.O. Box 525
Dover, Ohio 44622-0525

Dear Mr. Hall:

We have received your self-monitoring reports covering the months of June 2005 through May 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
June 2005:					
001	Week 3	Water Temperature	None	°C	Reporting required 1/week
001	Week 3	Dissolved Oxygen	None	mg/l	Reporting required 1/week
September 2005:					
001	Week 4	Water Temperature	None	°C	Reporting required 1/week
001	Week 4	Dissolved Oxygen	None	mg/l	Reporting required 1/week
November 2005:					
001	Average	Ammonia	3.16	mg/l	3.0
October 2006:					
001	Average	Fecal Coliform	2300	#/100ml	1000
001	10/17	Fecal Coliform	2300	#/100ml	2000
February 2007:					
001	Monthly	Ammonia	None	mg/l	Reporting required 1/month
July 2007:					
001	Average	Fecal Coliform	14600	#/100ml	1000
001	7/24	Fecal Coliform	14600	#/100ml	2000
001	Monthly	Ammonia	None	mg/l	Reporting required 1/month
August 2007:					
001	Monthly	Suspended Solids	None	mg/l	Reporting required 1/month
001	Monthly	Ammonia	None	mg/l	Reporting required 1/month

Outfall	Date	Parameter	Reported	Units	Permit Limitation
001	Monthly	Fecal Coliform	None	#/100ml	Reporting required 1/month
October 2007:					
001	Average	Fecal Coliform	3300	#/100ml	1000
001	Week 4	Fecal Coliform	3300	#/100ml	2000
December 2007:					
001	Monthly	Ammonia	None	mg/l	Reporting required 1/month
February 2008:					
001	Average	Ammonia	6.53	mg/l	3.0
001	Average	Ammonia	0.019	kg/day	0.017
001	2/19	Ammonia	6.53	mg/l	4.0
March 2008:					
001	Average	Ammonia	3.33	mg/l	3.0
001	Average	Suspended Solids	22	mg/l	12
001	3/4	Suspended Solids	22	mg/l	18
April 2008:					
001	Average	Suspended Solids	25	mg/l	12
001	Average	Suspended Solids	0.071	kg/day	0.0681
001	4/10	Suspended Solids	25	mg/l	18

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh

Enclosure

c: Mr. Ronald Lambert, Technical Supervisor