



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 7, 2008

Re: Tuscarawas County
Sandyville-East Sparta WWTP
Notice of Violation
OPJ00007, OH0048615
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer
Tuscarawas County Metropolitan Sewer District
9944 Wilkshire Blvd., NE
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of November 2007 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
March 2008					
001	Week 3	Suspended Solids	98.0	kg/day	85.3

We have received your report addressing the reasons for the aforementioned violation. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh

c: Mr. Jack Shalosky, Tuscarawas County Water and Sewer District