



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfeski, Director

July 23, 2009

**Re:** Tuscarawas County  
Sandyville-East Sparta WWTP  
Notice of Violation  
OPJ00007, OH0048615  
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer  
Tuscarawas County Metropolitan Sewer District  
9944 Wilkshire Blvd., NE  
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of November 2008 through May 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>March 2009:</b>					
001	Average	Suspended Solids	32	mg/l	30
001	Average	Suspended Solids	56.9	kg/day	56.8
001	Week 1	Suspended Solids	64	mg/l	45
001	Week 1	Suspended Solids	118	kg/day	85.3

We have received your report addressing the reasons for the aforementioned violation. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte  
Chemical Engineer - Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District