



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 23, 2010

**Re:** Tuscarawas County  
Stone Creek WWTP  
Notice of Violation  
OPA00104, OH0135348  
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer  
Tuscarawas County Metropolitan Sewer District  
9944 Wilkshire Blvd., NE  
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of February through July 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>February 2010</b>					
001	Average	Ammonia	8.24	mg/l	3.0
001	2/1	Ammonia	15.3	mg/l	4.5
<b>June 2010</b>					
001	6/15	CBOD <sub>5</sub>	17	mg/l	15
<b>July 2010</b>					
001	Average	Ammonia	12.1	mg/l	1.0
001	Average	Ammonia	0.36	kg/day	0.11
001	7/1	Ammonia	24.1	mg/l	1.5
001	7/1	Ammonia	0.73	kg/day	0.17

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte  
Chemical Engineer - Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District