



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 13, 2008

Re: Tuscarawas County
Sugar creek WWTP
Notice of Violation
OPB00070, OH0027618
Correspondence (PWW)

Mayor and Council
Village of Sugar creek
410 South Broadway
Sugar creek, Ohio 44681

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of September 2006 through May 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
September 2006:					
001	Week 3	CBOD ₅	1/week	mg/l	Reporting required 2/week
October 2006:					
001	Week 4	CBOD ₅	1/week	mg/l	Reporting required 2/week
January 2007:					
001	Week 2	Suspended Solids	40	kg/day	34
March 2007:					
601	Week 4	CBOD ₅	1/week	mg/l	Reporting required 2/week
June 2007:					
001	Week 3	Ammonia	3.71	kg/day	3.5
001	Week 4	CBOD ₅	1/week	mg/l	Reporting required 2/week
October 2007:					
001	8 Days	pH	None	S.U.	Reporting required 1/day
001	8 Days	Dissolved Oxygen	None	mg/l	Reporting required 1/day
November 2007:					
001	Week 4	Suspended Solids	35.6	kg/day	34
December 2007:					
001	11 Days	pH	None	S.U.	Reporting required 1/day
February 2008:					
001	Week 1	Suspended Solids	19	mg/l	18
001	Week 1	Suspended Solids	52	kg/day	34

Please review the reported flow rates for December 2007. A review of these values reveals the flow rates ranged between 294 and 765 MGD. Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer, Environmental Specialist II
Division of Surface Water

JMW/dh

- c: Mr. Jim Cappon, Superintendent of Wastewater, Village of Sugarcreek
- c: Mr. Clayton Weller, Village Administrator, Village of Sugarcreek