



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 21, 2009

Re: Tuscarawas County
Sugar creek WWTP
Notice of Violation
OPB00070, OH0027618
Correspondence (PWW)

Mayor and Council
Village of Sugar creek
410 South Broadway
Sugar creek, Ohio 44681

Dear Mayor and Council:

We have received your self-monitoring report covering the month of October 2006 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

October 2006:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
001	Week 1	Ammonia	5.0	mg/l	3.5


Please review your December 2007 discharge monitoring report. A review of the document reveals that the flow rates were reported in gallons per day rather than million gallons per day. As a result, there are numerous loading violations being alleged. Please change the flow rates to million gallons per day and resubmit the document to reflect the correct information in the system.

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the October 2006 referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer, Environmental Specialist II
Division of Surface Water

JMW/dh

- c: Mr. Jim Cappon, Superintendent of Wastewater, Village of Sugarcreek
- c: Mr. Clayton Weller, Village Administrator, Village of Sugarcreek