



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 23, 2010

**Re:** Tuscarawas County  
Sugarcreek WWTP  
Notice of Violation  
OPB00070, OH0027618  
Correspondence (PWW)

Mayor and Council  
Village of Sugarcreek  
410 South Broadway  
Sugarcreek, Ohio 44681

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of February through July 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>July 2010:</b>					
001	7/5	Phosphorus, Total	2.11	mg/l	1.0

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the October 2006 referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte  
Chemical Engineer, Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Jim Cappon, Superintendent of Wastewater, Village of Sugarcreek