



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

October 19, 2007

Re: Tuscarawas County
Twin City WWTP
Notice of Violation (OPD00015, OH0020079)
Correspondence (PWW/Major)

Mr. John O'Hara, President of the Board
Twin City Water and Sewer District
308 Grant Street
Dennison, Ohio 44621

Dear Mr. O'Hara:

We have received your self-monitoring reports covering the months of February through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
February 2007:					
001	Week 4	Ammonia	None	mg/l	Monitoring required 3/week
March 2007:					
001	3/1&3/22	pH, Maximum	None	S.U.	Reporting required 1/day
001	3/1&3/22	pH, Minimum	None	S.U.	Reporting required 1/day
001	3/1&3/22	Water Temperature	None	S.U.	Reporting required 1/day
001	3/1&3/22	Dissolved Oxygen	None	S.U.	Reporting required 1/day
001	3/22	Flow Rate	None	S.U.	Reporting required 1/day
586	Weeks 1-3	Percent Total Solids	None	%	Reporting required 1/week
586	Weeks 1-3	Sludge Weight	None	Dry Tons	Reporting required 1/week
April 2007:					
586	Week 3	Percent Total Solids	None	%	Reporting required 1/week
586	Weeks 1&3	Sludge Weight	None	Dry Tons	Reporting Required 1/week
May 2007:					
001	Week 2	Ammonia	2/Week	mg/l	Monitoring required 3/week
001	Week 2	CBOD ₅	2/Week	mg/l	Monitoring Required 3/week
586	Week 3	Percent Total Solids	None	%	Reporting required 1/week
586	Week 3	Sludge Weight	None	Dry Tons	Reporting required 1/week
August 2007:					
001	Weeks 1-2	Oil and Grease	None	mg/l	Monitoring required ½ weeks
001	Week 3	Fecal Coliform	AK	#/100ml	2000
September 2007:					
001	9/19	Chlorine Residual	0.13	mg/l	0.029
001	Week 4	CBOD ₅	2/Week	mg/l	Reporting required 3/week
601	Week 4	CBOD ₅	2/Week	mg/l	Reporting required 3/week

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the aforementioned referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions. In addition, please resubmit the August 2004 metals data by creating a new zip file.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer, Environmental Specialist II
Division of Surface Water

JMW/dh

- c: Mr. John Rypien, Superintendent, Twin City Water and Sewer District
- c: Mr. Donald C. Fawcett, Assistant Superintendent, Twin City Water and Sewer District