



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 1, 2009

**Re:** Tuscarawas County  
Twin City WWTP  
Notice of Violation  
OPD00015, OH0020079  
Correspondence (PWW/Major)

Mr. John O'Hara, President of the Board  
Twin City Water and Sewer District  
308 Grant Street  
Dennison, Ohio 44621

Dear Mr. O'Hara:

We have received your self-monitoring reports covering the months of May through August 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>July 2009:</b>					
001	7/16	Oil and Grease	23	mg/l	10

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte  
Chemical Engineer, Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Donnie Fawcett, Assistant Supt., Twin City Water & Sewer District