



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 3, 2007

Re: Tuscarawas County
Wilkshire Hills WWTP
Notice of Violation; OPJ00008, OH0076261
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer
Tuscarawas County Metropolitan Sewer District
9944 Wilkshire Blvd., NE
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of January 2006 through August 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
January 2006					
581	Monthly	Percent Total Sludge	1/Month	%	Monitoring required 1/month
581	Monthly	Percent Volatile Sludge	1/Month	%	Monitoring required 1/month
May 2007					
001	5/2	Fecal Coliform	AK	#/100ml	2000

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh.

c: Mr. Don Wolfe, Tuscarawas County Water and Sewer District