



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 23, 2009

**Re:** Tuscarawas County  
Wilkshire Hills WWTP  
Notice of Violation  
OPJ00008, OH0076261  
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer  
Tuscarawas County Metropolitan Sewer District  
9944 Wilkshire Blvd., NE  
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of August through October 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<i>September 2009:</i>					
001	9/2	Oil and Grease	19.4	mg/l	10

We have received your report addressing the reason for the above violations and actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte  
Chemical Engineer - Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Don Wolfe, Tuscarawas County Water and Sewer District