



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

March 9, 2011

**Re:** Tuscarawas County  
Wilkshire Hills WWTP  
Notice of Violation; OPJ00008, OH0076261  
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer  
Tuscarawas County Metropolitan Sewer District  
9944 Wilkshire Blvd., NE  
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring report covering the month of December 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
001	12/6	Arsenic, Total	78.2	mg/kg	75

We have reviewed your report addressing the reason for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte  
Chemical Engineer - Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District