



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 1, 2009

**Re:** Tuscarawas County  
Twin City WTP  
Notice of Violation  
OIV00100, OH0029815  
Correspondence (IWW)

Mr. John O'Hara, President of the Board  
Twin City Water and Sewer District  
308 Grant Street  
Dennison, Ohio 44621

Dear Mr. O'Hara:

We have received your self-monitoring reports covering the months of October 2008 through August 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>June 2009:</b>					
002	6/29-6/30	Flow Rate	None	GPD	Reporting required 1/day
<b>August 2008:</b>					
001	8/25	Suspended Solids	7.55	kg/day	7.15

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

A handwritten signature in cursive script that reads "Jennifer M. Witte".

Jennifer M. Witte  
Chemical Engineer, Environmental Specialist II  
Division of Surface Water

JMW/dh

- c: John Rypien, Superintendent, Twin City Water & Sewer District
- c: Brett Long, Supervisor, Twin City WTP