



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

September 11, 2007

Re: Tuscarawas County
Boltaron Performance Products, LLC
Notice of Violation (0IQ00019, OH0004430)
Correspondence (IWW)

Mr. Tim Ohler, Environmental/Safety Engineer
Boltaron Performance Products, LLC
One General Street
Newcomerstown, Ohio 43832

Dear Mr. Ohler:

We have received your self-monitoring report covering the month of March 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
001	3 Days	pH	9.82-10.84	S.U.	9.0 Maximum

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/mlm