



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 14, 2007

Re: Tuscarawas County
Dover Chemical Corporation
Notice of Violation
OIF00040, OH0007269
Correspondence (IWW/Major)

Mr. W. Patrick Huth, EH&S Manager
Dover Chemical Corporation
3676 Davis Road NW
P.O. Box 40
Dover, Ohio 44622

Dear Mr. Huth:

We have received your self-monitoring reports covering the months of August and September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

[Outfall]	Date	Parameter	Reported	Units	Permit Limitation
August 2007:					
002	Week 1	Chlorine Residual	1/Week	mg/l	Monitoring required 2/week
602	8/27	Fecal Coliform	15000	#/100ml	2000
602	Average	Fecal Coliform	15000	#/100ml	1000
September 2007:					
602	Average	Fecal Coliform	1200	#/100ml	1000

Please be advised that Part III, Item 1 of your permit defines a calendar week under "average weekly" as follows:

- Week 1 is Days 1-7 of the month
- Week 2 is Days 8-14 of the month
- Week 3 is Days 15-21 of the month
- Week 4 is Days 22-28 of the month

Please inform this office in writing within **ten days** of receipt of this notification as to the reasons for the referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.


Dover Chemical Corp.

Page 2

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Handwritten signature of Jennifer M. Witte in cursive script.

Jennifer M. Witte
Chemical Engineer, Environmental Specialist II
Division of Surface Water

JMW/dh