



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 15, 2008

**Re:** Tuscarawas County  
Dover Chemical Corporation  
Notice of Violation  
OIF00040, OH0007269  
Correspondence (IWW/Major)

Mr. Dwain Colvin, Plant Manager  
Dover Chemical Corporation  
3676 Davis Road NW  
P.O. Box 40  
Dover, Ohio 44622

Dear Mr. Colvin:

We have received your self-monitoring reports covering the months of October 2007 through May 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>December 2007:</b>					
002	Quarterly	PCB's	None	mg/l	Reporting required 1/quarter
<b>February 2008:</b>					
002	Average	Chlorine Residual	0.22	mg/l	0.017
002	2/6	Chlorine Residual	2.2	mg/l	0.027
<b>March 2008:</b>					
002	3/5	Carbon Tetrachloride	1.41	kg/day	0.76
002	3/5	Carbon Tetrachloride	84	ug/l	44

Please inform this office in writing within **ten days** of receipt of this notification as to the reasons for the referenced violations, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte  
Chemical Engineer, Environmental Specialist II  
Division of Surface Water

JMW/dh