



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 1, 2010

Re: Tuscarawas County
Dover Chemical Corporation
Notice of Violation
OIF00040, OH0007269
Correspondence (IWW/Major)

Ms. Melissa Clark-Dross, EH&S Manager
Dover Chemical Corporation
3676 Davis Road NW
Dover, Ohio 44622

Dear Ms. Clark-Dross:

We have received your self-monitoring reports covering the months of February through April 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<i>February 2010:</i>					
002	2/8	pH, Minimum	6.44	S.U.	6.5 Minimum
002	2/15	pH, Minimum	6.31	S.U.	6.5 Minimum

We have received a report addressing the aforementioned violations. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte
Chemical Engineer, Environmental Specialist II
Division of Surface Water

JMW/dh

c: Gary Phillips, Regulatory Compliance Coordinator