

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 25, 2011

**Re:** Tuscarawas County  
Dover Chemical Corporation  
Notice of Violation  
OIF00040, OH0007269  
Correspondence (IWW/Major)

Ms. Melissa Clark-Dross, EH&S Manager  
Dover Chemical Corporation  
3676 Davis Road NW  
Dover, Ohio 44622

Dear Ms. Clark-Dross:

We have received your self-monitoring reports covering the months of October and November 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>October 2010:</b>					
002	Average	Chloroform	412	ug/l	44
002	Average	Chloroform	7.87	kg/day	0.76
002	10/4	Carbon Tetrachloride	300	ug/l	44
002	10/4	Carbon Tetrachloride	5.72	kg/day	0.76
002	10/4&10/6	Chloroform	1.56-59.1	kg/day	1.14
002	10/4&10/6	Chloroform	78-3100	ug/l	67

We have received the reports addressing the aforementioned violations. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte  
Chemical Engineer, Environmental Specialist II  
Division of Surface Water

JMW/dh

c: Gary Phillips, Regulatory Compliance Coordinator