



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 4, 2013

RE: PORTAGE COUNTY
CITY OF STREETSBORO
COMMUNITY WATER SYSTEM
PWS ID #OH6705003

CERTIFIED MAIL 7010106000000898480

Mr. John Kuklisin, Superintendent
City of Streetsboro
2094 S.R. 303
Streetsboro, OH 44241

RE: NOTICE OF VIOLATION - CHLORINE RESIDUAL

Dear Mr. Kuklisin:

This letter is notification that the City of Streetsboro public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information reported on *2012 Monthly Operating Reports (MORs)*. Data reported on these forms documented that the minimum free chlorine residual was not maintained as required, resulting in four violations in January, four violations in March, two violations in April, one violation in June, one violation in August, one violation in October, one violation in November, and four violations in December.

Within thirty (30) days of the receipt of this letter, a written response must be received documenting the steps that will be taken to resolve these violations and ensure that the City of Streetsboro public water system will remain in compliance with OAC 3745-83-01(C)(1). Continued violations will result in further enforcement actions.

If you have any questions, I can be contacted directly at (330) 963-1235.

Respectfully,

Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

cc: Mr. William Miller, Service Director
The Honorable Mayor Glenn Broska