



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 21, 2008

**Re: Vinton County
Lake Hope State Park
Self-Monitoring Report Violations
NPDES Permit #OPP00066 & OPP00067
Correspondence (PWW)**

Mr. Randy Zeisler, Manager
Lake Hope State Park
27331 State Route 278
McArthur, Ohio 45651

Dear Mr. Zeisler:

We have received your self-monitoring report covering the months of April through August for the Lodge Hill Cabins wastewater treatment plant (OPP00066) and Old Hill Cabins wastewater treatment plant (OPP00067). Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Lodge Hill Plant, NPDES OPP00066:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	15.6	4/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.06	.88569	4/1/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	4.4	4/4/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	15.6	4/8/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.09	.88569	4/8/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	4.8	4/22/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	5/6/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	4.6	5/21/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	5/27/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	4.4	5/27/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.2	6/6/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2	51.7	8/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3	51.7	8/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.11	2.93527	8/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.17	2.93527	8/1/2008
001	31616	Fecal Coliform	30D Conc	1000	7000.	8/1/2008
001	31616	Fecal Coliform	7D Conc	2000	7000.	8/1/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	5.	8/5/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	1.	8/28/2008

Old Hill Cabins, NPDES No. 0PP00067:


Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	9.88	5/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.04	.37396	5/1/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	5/6/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	9.88	5/8/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.06	.37396	5/8/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	5/27/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	6/6/2008
001	00300	Dissolved Oxygen	1D Conc	6.0	2.	6/6/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	7/3/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.2	7/17/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	8/5/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have spoken with Greg Masterson about the current problems with the wastewater treatment plants and he assured me they are trying to operate the plants as effectively as possible. We have the request for revisions for the plans for the new sewer and wastewater treatment plant. However, you must, within ten days of receipt of this notification, list the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations.

If there are any questions, please contact me at (740) 380-5266.

Sincerely,



Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh

c: Greg Masterson, ODNR, Division of Engineering