



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

March 20, 2008

**RE: WASHINGTON COUNTY
VILLAGE OF BEVERLY
COMPLIANCE EVALUATION
INSPECTION
CORRESPONDENCE (PWW)**

Mr. Jim Ullman, President
Board of Public Affairs
Village of Beverly
919 Mitchell Avenue
Beverly, OH 45715

Dear Mr. Ullman:

On February 28, 2008, a Compliance Evaluation Inspection (CEI) was conducted at the Village of Beverly's wastewater treatment plant. The purpose of the inspection was to determine Beverly's compliance with its National Pollutant Discharge Elimination System (NPDES) Permit. Present for the inspection were Sam Booker, Bryan Jarvis and Kevin Tornes, representing Beverly and Stephen Wells representing Ohio EPA, Division of Surface Water, Southeast District Office. No wastewater samples were collected as part of the inspection. A copy of my inspection is attached.

As a result of my inspection, I have the following comments:

1. The Village is planning on starting upgrades to the wastewater treatment plant. The upgrades will include the installation of a sludge press and UV disinfection. The treatment tanks will also be rehabbed as part of the upgrade.
2. The NPDES Permit requires a 24-hour composite sampling of the discharge from the plant. Please inform this office when a 24-hour composite sampler has been installed.
3. The treatment plant has a flow meter only at the influent of the plant. The NPDES Permit requires flow be monitored at the discharge of the plant. Please inform this office when an effluent flow meter will be installed.
4. The Village has been working on removing inflow/infiltration (I/I) from its collection system. The Village is planning on doing additional smoke testing and televising of the collection system. Please update this office on the status of the I/I removal.

Mr. Jim Ullman, President
Village of Beverly
March 20, 2008
Page 2

5. The Village has had problems meeting the NPDES Permit effluent limitations for fecal coliform in the past year. The installation of the sludge press and UV disinfection system should help address these violations.
6. During the construction of the upgrades, Beverly stated it will not be possible to use the dechlorination unit at the facility. Beverly needs to evaluate how dechlorination can be accomplished on a temporary basis during this time. This may include using a portable pump to dechlorinate the effluent. Please inform this office what possible alternatives may be available.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

In conclusion, the Village of Beverly appeared to be in marginal compliance with its NPDES Permit at the time of the inspection.

Please respond to the above comments in writing to this office within 20 days of receipt of this letter.

If you have any questions, feel free to contact me at (740) 380-5434.

Sincerely,



Stephen Wells
District Representative
Division of Surface Water

SW/mlm

Attachment

c: Kevin Tornes, Operator

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPB00002*GD	OH0020648	February 28, 2008	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Beverly Wastewater Treatment Plant 522 State Route 60 Beverly, Ohio 45715	8:30 a.m.	April 4, 2003
	Exit Time	Permit Expiration Date
	10:00 a.m.	March 31, 2008

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Kevin Tornes, Operator	(740) 984-1052
Name, Address and Title of Responsible Official	Phone Number
Jim Ullman, President Village of Beverly Board of Public Affairs 919 Mitchell Avenue Beverly, Ohio 45715	(740) 984-1052

C. AREAS EVALUATED DURING INSPECTION

- | | | |
|--------------------------------------|---------------------------------------|-------------------------------------|
| <u> </u> S Permit | <u> </u> S Flow Measurement | <u> </u> N/A Pretreatment |
| <u> </u> S Records/Reports | <u> </u> N Laboratory | <u> </u> N/A Compliance Schedules |
| <u> </u> S Operations & Maintenance | <u> </u> M Effluent/Receiving Waters | <u> </u> M Self-Monitoring Program |
| <u> </u> S Facility Site Review | <u> </u> N/A Sludge Storage/Disposal | <u> </u> Other |
| <u> </u> N Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



 Stephen Wells, Inspector, Ohio EPA, Southeast District Office

3/20/08

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/20/08

 Date