



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 9, 2010

**Re: Washington County
4-Mor Storage
Self-Monitoring Report Violations
Ohio EPA Permit No.0PW00083*AD
NPDES Permit No. OH0135364
Correspondence (PWW)**

Mr. Tom Kern
4-Mor Storage
3396 Waterford Road
Marietta, Ohio 45750

Dear Mr. Kern:

We have received your self-monitoring report covering the months of December 2009 through March 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Dissolved Oxygen	1D Conc	6.0	1.	12/1/2009
001	Dissolved Oxygen	1D Conc	6.0	1.	12/8/2009
001	Dissolved Oxygen	1D Conc	6.0	1.	12/15/2009
001	Dissolved Oxygen	1D Conc	6.0	1.	12/22/2009
001	Dissolved Oxygen	1D Conc	6.0	1.	12/29/2009
001	Total Suspended Solids	30D Conc	12	51.	12/1/2009
001	Total Suspended Solids	1D Conc	18	51.	12/9/2009
001	Nitrogen, Ammonia (NH3)	30D Qty	0.018	.03252	12/1/2009
001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	45.7	12/1/2009
001	Nitrogen, Ammonia (NH3)	1D Conc	4.5	45.7	12/9/2009
001	Nitrogen, Ammonia (NH3)	1D Qty	0.027	.03252	12/9/2009
001	CBOD 5 day	30D Conc	10	139.	12/1/2009
001	CBOD 5 day	30D Qty	0.059	.09891	12/1/2009
001	CBOD 5 day	1D Qty	0.089	.09891	12/9/2009
001	CBOD 5 day	1D Conc	15	139.	12/9/2009
001	Dissolved Oxygen	1D Conc	6.0	4.79	3/18/2010
001	Total Suspended Solids	30D Conc	12	32.	3/1/2010
001	Total Suspended Solids	1D Conc	18	32.	3/10/2010
001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	24.7	3/1/2010
001	Nitrogen, Ammonia (NH3)	30D Qty	0.018	.02851	3/1/2010
001	Nitrogen, Ammonia (NH3)	1D Conc	4.5	24.7	3/10/2010
001	Nitrogen, Ammonia (NH3)	1D Qty	0.027	.02851	3/10/2010
001	CBOD 5 day	30D Qty	0.059	.086	3/1/2010
001	CBOD 5 day	30D Conc	10	74.5	3/1/2010
001	CBOD 5 day	1D Conc	15	74.5	3/10/2010

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5434.

Sincerely,



Stephen Wells
District Representative
Division of Surface Water

SW/dh